

KRT2024-04 Roof Replacement Addendum 1

1. 1/8", or approved equal, cricket system may be added as an additional option around the drainage areas on the roof.
2. Clarification that the EPDM will be adhered to the mechanically fastened 3" ISO.
3. Adding additional attached form that must be signed that verifies offeror checked www.rideonkrt.com/rfp for addendum information.

Offeror Representative Signature

Offeror Representative Name and Title

Offeror Company

Date

KRT Information Verification

I, _____, certify that I referenced www.rideonkrt.com/rfp for all proper forms, addendums, and any other information regarding this RFP.

Offeror Representative Signature

Offeror Representative Name and Title

Offeror Company

Date